



1. Somke alarm , default : NC, remove jumper to connect alarm;
2. The transformer input side 3 and 5 terminals to add short wiring 14AWG ;
3. The transformer output side 10 and 11 terminals to add short wiring 12AWG ;

Wiring Diagram

PART#:1170105550